

Needs and Opportunities to Improve RHC Performance Metrics

Renewable Heating &
Cooling Workshop
JUN 18-19 // SARATOGA SPRINGS, NY

Ground Source Heat Pumps: Challenges and Opportunities

J. Matthew Davis



University of New Hampshire

Ground Energy Support LLC




The problem with COP....

ΔT and corresponding error depends on:
heat pump equipment, system design, and installation



The problem with COP....




Residential Ground Source Heat Pump Study:
A Comprehensive Assessment of Performance,
Emissions, and Economics




UNIVERSITY OF MINNESOTA
Driven to DiscoverSM

Rethink EM&V for Ground Source Heat Pump Systems


- Overreliance on 'COP'
 - Relies upon measurements of:
 q , ΔT , kW
- Consider all system components
 - Heat pump equipment
 - Ground loop
 - Building envelope
 - System design
 - User operation
 - Weather conditions
- Uncertainty and Risk
- Need quantitative performance metrics with risk attribution



Conceptual Framework – the Hypothesis



Example Analysis: Single Family Ranch House Coos County NH




- COP appears to be below expected
- Potential factors:
 - Heat pump
 - Ground loop
 - Building
 - Occupant

Hourly Entering Water Temperature (EWT) for Heating and Cooling Modes

Selected GES installations

Calendar Year 2016



Observed low EWT

Heat Pump Model


Section 6c: Model 036C Performance Data: 3.0 Ton,
Part Load, 1050 CFM Cooling / 1050 CFM Heating

EWT °F	Flow GPM	WPD PSI	FT	Heating						Cooling					
				Airflow CFM	HC MBtuh	HE MBtuh	LAT °F	COP W/W	DH MBtuh	Airflow CFM	TC MBtuh	SC MBtuh	S/T	HR MBtuh	EER Btu/h/W
25	7.0	2.5	5.8	1050	17.3	11.9	85.3	1.58	3.21	2.3					
				950	16.8	11.2	86.4	1.63	3.02	2.2					
				1050	18.6	13.2	86.4	1.59	3.43	2.5					
30	5.0	1.4	3.3	950	18.1	12.5	87.6	1.65	3.21	2.4					
				1050	18.8	13.4	86.6	1.59	3.46	2.5					
				950	18.3	12.7	87.8	1.65	3.25	2.4					
40	5.0	1.3	3.0	1050	18.8	13.4	86.6	1.59	3.46	2.5					
				950	18.3	12.7	87.8	1.65	3.25	2.4					
				1050	22.0	16.5	89.4	1.62	3.98	2.9					
50	6.0	1.7	3.9	950	21.4	15.7	90.9	1.68	3.73	2.9					
				1050	22.2	16.7	89.6	1.62	4.02	2.9					
				950	21.7	16.0	91.2	1.68	3.78	2.9					
60	7.0	2.2	5.0	1050	22.4	16.9	89.8	1.62	4.05	2.9					
				950	21.8	16.1	91.2	1.68	3.80	3.1					
				1050	25.5	19.9	92.5	1.65	4.53	3.4	1050	32.0	22.2	0.69	35.6
70	5.0	1.2	2.7	950	24.8	19.0	94.2	1.71	4.25	3.3	950	30.8	20.7	0.67	34.5
				1050	25.7	20.1	92.7	1.65	4.56	3.4	1050	32.3	22.2	0.69	35.8
				950	25.0	19.2	94.4	1.71	4.28	3.3	950	31.2	20.7	0.66	34.8
80	6.0	1.6	3.6	1050	25.9	20.3	92.8	1.65	4.60	3.4	1050	32.7	22.4	0.69	36.1
				950	25.2	19.4	94.6	1.71	4.32	3.3	950	31.5	20.9	0.66	35.0
				1050	28.7	23.0	95.3	1.67	5.04	3.8	1050	30.2	21.4	0.71	34.3
90	5.0	1.1	2.5	950	28.0	22.1	97.3	1.73	4.74	3.8	950	29.1	20.0	0.69	33.3
				1050	29.0	23.3	95.6	1.68	5.06	3.8	1050	30.5	21.5	0.70	34.5
				950	28.3	22.4	97.6	1.73	4.79	3.8	950	29.5	20.0	0.68	33.6
100	6.0	1.5	3.4	1050	29.2	23.5	95.7	1.68	5.09	3.8	1050	30.9	21.6	0.70	34.9
				950	28.6	22.8	97.0	1.73	4.81	3.8	950	29.9	20.5	0.69	33.9
				1050	32.0	26.0	96.0	1.65	5.70	4.2	1050	33.0	24.0	0.70	36.0




Database Structure Browse Data Edit Pragmas Execute SQL												
Table: Hydron_HXT_036_PL												
Index	EWT [F]	Flow [GPM]	WPD [PSI]	Airflow [CFM]	HC [MBtuh]	HE [MBtuh]	LAT [F]	HE kW	COP	DH [MBtuh]	Airflow [CFM]	WPD [PSI]
Filter	Filter	Filter	Filter	Filter	Filter	Filter	Filter	Filter	Filter	Filter	Filter	Filter
1	0	25.0	7.0	2.5	1050	17.3	11.9	85.3	1.58	3.21	2.3	NULL
2	1	25.0	7.0	2.5	950	16.8	11.2	86.4	1.63	3.02	2.2	NULL
3	2	30.0	5.0	1.4	1050	18.6	13.2	86.4	1.59	3.43	2.5	NULL
4	3	30.0	5.0	1.4	950	18.1	12.5	87.6	1.65	3.21	2.4	NULL
5	4	30.0	6.0	1.9	1050	18.8	13.4	86.6	1.59	3.46	2.5	NULL
6	5	30.0	6.0	1.9	950	18.3	12.7	87.8	1.65	3.25	2.4	NULL
7	6	30.0	7.0	2.4	1050	18.8	13.4	86.6	1.59	3.46	2.5	NULL
8	7	30.0	7.0	2.4	950	18.3	12.7	87.8	1.65	3.25	2.4	NULL
9	8	40.0	5.0	1.3	1050	22.0	16.5	89.4	1.62	3.98	2.9	NULL
10	9	40.0	5.0	1.3	950	21.4	15.7	90.9	1.68	3.73	2.9	NULL
11	10	40.0	6.0	1.7	1050	22.2	16.7	89.6	1.62	4.02	2.9	NULL
12	11	40.0	6.0	1.7	950	21.7	16.0	91.2	1.68	3.78	2.9	NULL
13	12	40.0	7.0	2.2	1050	22.4	16.9	89.8	1.62	4.05	2.9	NULL
14	13	40.0	7.0	2.2	950	21.8	16.1	91.2	1.68	3.8	3.1	NULL


Heating Part Load




Heating Full Load




Heating kW v. EWT



Heat Extraction v. EWT




Ground Loop Model



Optimal parameters :

$$R_b = 0.025 \text{ Cm/W}$$


$$K_T = 1.5 \text{ W/mC}$$



Demand Model



Demand on ground loop for heat appears to be greater than design.

No cooling enhances annual imbalance (NAGL).



Performance of Site 1660

- Heat pump
 - Operating within expected ranges
- Ground loop:
 - Lower than expected thermal K
 - Low borehole resistance (good)
- Demand
 - Homeowner does not use AC
 - Higher than expected heating load on ground loop



Challenges with Commercial GSHP Applications


- GES monitoring five commercial-scale buildings
 - Mixed Residential-Commercial Building (New)
 - Distributed heat pumps (10), large pumping penalty
 - Town Library (Retrofit)
 - Centralized heat pumps (2 10-ton units)
 - County Correctional Facility (New)
 - Centralized 'multi-stack' (12 10-ton units), intermingling of propane backup may be an issue
 - Multi-story climate-controlled self storage (New)
 - Distributed water-to-air heat pumps (9), highly efficient pumping, no back-up system.
 - Multi-unit (multistory) low-income housing (New)
 - Distributed water-to-air heat pumps (~40) make it difficult to quantify usage/savings.
- Highly variable design, installation, operation

Challenges with Heat Meters in RTT systems




Onicon System 10 Heat Meter – One of the Best on the Market




Site A




Site B



oTherm Initiative



oTherm Initiative

- 
- Data models for RTTs, GSHP use case
 - Consensus on best practices
 - APIs to connect databases
 - Build oTherm platform and launch

Conclusions

- Performance verification is needed to build confidence and demonstrate benefits.
- Efforts should focus on factors that are both measureable and provide insight.
- Small systems may more amenable to standardized approach.
- oTherm initiative is a community-driven effort standardize data dictionaries and aggregate data.

oTherm Initiative

HPXML is standardized data exchange protocol (XML), focused on home performance (HP)

Built using elements from BEDES data Dictionary.

The screenshot shows the HPXML Toolbox interface. The top navigation bar includes 'Validator', 'Data Dictionary', 'Mapping', and 'Search'. The 'Data Dictionary' tab is active, showing the 'HPXML' section. A description box states 'Root element in HPXML.' To the right, a table lists 'Use Cases / Standard Data Sets' with four entries: 'Audit', 'Upgrade', 'Home Energy Score', and 'Home Performance Certificate (BPI-2101)', each marked with a green checkmark. The version is noted as '2.2.1'. An annotation box at the bottom left highlights the 'HPXML Data Dictionary' and 'oTherm Data Dictionary' tabs, with an arrow pointing to the 'oTherm Data Dictionary' tab and the text 'New HPXML Use Case for RTT'.

HPXML Toolbox

NREL
NATIONAL RENEWABLE ENERGY LABORATORY

</> Validator ▾ Data Dictionary Mapping ▾ Search

Sign Up Login

HPXML

Version: 2.2.1 ▾

Description ⓘ

Root element in HPXML.

Use Cases / Standard Data Sets ⓘ


Audit	✓
Upgrade	✓
Home Energy Score	✓
Home Performance Certificate (BPI-2101)	✓

HPXML Data Dictionary

oTherm Data Dictionary

New HPXML Use Case for RTT

oTherm Initiative




The Coefficient of Performance (COP)

$$\text{COP} = \frac{\text{HE} + 3412 \cdot \text{kW}_{\text{in}}}{3412 \cdot \text{kW}_{\text{in}}}$$

$$\text{HE} = c \cdot Q_f \cdot [T_{\text{in}} - T_{\text{out}}]$$

$$\text{HE} = c \cdot Q_f \cdot \Delta T$$



Sources of Error when calculating COP

- Temperature (ΔT)
 - Ground loop flowrate (Q_f)
 - kW (compressor and electric auxiliary)
 - kW (circulating pumps, fans)
- } GeoExchange (HE)

Measurement Error Model

Propagation of Sensor Errors

$N_{obs} = 74923$ $N_{real} = 1000$
 $\sigma_T = 0.05$ [°C] $\sigma_Q = 0.04$ [gpm]: $kW_{err} = 0.5\%$

$N_{obs} = 8659$ $N_{real} = 1000$
 $\sigma_T = 0.25$ [°C] $\sigma_Q = 1.0$ [gpm]: $kW_{err} = 10.0\%$

